International Journal of Engineering Research and Science & Technology

www.ijerst.org

ISSN : 2319-5991

Vol. 21 No. 4 (2025)



ijerst.editor@gmail.com

editor@ijerst.com

International Journal of Engineering Research and Science & Technology

ISSN 2319-5991 www.ijerst.com
Vol. 21, No. 4, 2025
© 2025 IJERST. All Rights Reserved

Research Paper

ADVANCED ENERGY COORDINATION FOR HYBRID RENEWABLE SYSTEMS

E . Sriram[(a)], Dr. M. Kondalu[b)]

PG Scholar, EEE Department, Malla Reddy Engineering College, Hyderabad, sriramesampelli@gmail.com

Professor, EEE Department, Malla Reddy Engineering College, Hyderabad, drkondalu@gmail.com.

Abstract: The increasing demand for clean and reliable energy has accelerated the development of hybrid renewable power systems. This study presents an Advanced Energy Coordination strategy for a hybrid photovoltaic (PV), wind, and fuel cell system designed to improve power reliability, efficiency, and system stability under varying environmental conditions. The proposed framework integrates advanced power conditioning, intelligent load sharing, and an optimized control strategy to manage the intermittent nature of PV and wind sources while utilizing the fuel cell as a stable backup unit. The system ensures balanced power flow by dynamically adjusting energy contributions based on real-time generation and load requirements. Simulation results demonstrate significant improvements in voltage regulation, reduced power fluctuations, and better utilization of renewable resources compared to conventional distribution methods. The enhanced energy distribution model offers a robust solution for sustainable energy applications, microgrid development, and rural electrification scenarios.

Keywords: Hybrid Renewable Energy System, Photovoltaic (PV), Wind Energy, Fuel Cell, Energy Distribution, Power Management, Microgrid, Sustainable Energy.

Received: 19-10-2025 Accepted: 29-11-2025 Published: 08-12-2025

I. INTRODUCTION

The growing global demand for clean, reliable, and sustainable energy has accelerated the transition from conventional fossil-fuel-based power generation to renewable energy systems. Among various renewable sources, solar photovoltaic (PV), wind, and fuel cell technologies have gained significant attention due to their environmental benefits, abundant availability, and capability to operate in decentralized configurations. However, the intermittent and unpredictable nature of solar and wind energy poses major challenges to maintaining power quality, voltage stability, and continuous energy supply.

Hybrid renewable systems offer a practical solution by combining multiple energy sources to complement each other's limitations. In particular, integrating PV, wind, and fuel cell units creates a robust multi-source energy platform capable of delivering stable and efficient power under varying climatic conditions. Effective coordination of these energy sources is critical to ensure optimal power flow, improved reliability, and enhanced overall system performance.

Advanced energy coordination strategies employ intelligent power management algorithms, real-time control mechanisms, and optimized energy distribution frameworks to balance generation variability and meet load demands efficiently. These strategies minimize power fluctuations, reduce dependency on energy storage systems, and enhance the system's ability to respond to dynamic load changes.

This study focuses on developing an advanced coordination mechanism for hybrid renewable systems by systematically managing energy contributions from PV, wind, and fuel cell units. The objective is to achieve improved energy stability, higher efficiency, and seamless integration of multiple renewable sources, ultimately contributing to the development of resilient and sustainable power networks.

The provided images illustrate the structural and functional arrangement of hybrid renewable

energy systems that integrate photovoltaic (PV), wind, and auxiliary power units such as fuel cells or storage devices. These diagrams visually represent how multiple renewable energy sources can be combined to enhance system reliability, stability, and efficiency.




Figure.1 : Hybrid Renewable Systems

Figure.1 shows the block diagrams highlight the flow of energy from various sources—solar panels, wind turbines, and fuel cells—into power conditioning units such as converters, controllers, and energy management modules. These components work together to ensure that energy is distributed optimally to meet load demands while maintaining power quality. The images also demonstrate the coordinated operation of different sources under varying environmental conditions, showcasing the advantages of hybridization in minimizing power fluctuations and improving system resilience.

II. SYSTEM MODELLING AND CONTROL

A hybrid microgrid where PV and wind supply variable renewable power, a fuel cell provides dispatchable backup, and power converters + an EMS coordinate sources through a common DC bus and an inverter feeding AC loads. Optionally include a battery/supercapacitor for transient support in shown as Figure 2.




Figure 2: Conceptual block diagram

1.Control Equations

A. Photovoltaic (single-diode model):

Use the single-diode I–V model for PV string:

$$I = I_{ph} - I_0[\exp(\frac{V + IR_s}{nV_T}) - 1] - \frac{V + IR_s}{R_{sh}}$$

Where:

- I_{ph}= light-generated current (depends on irradiance G): $I_{ph} = I_{ph,ref}\frac{G}{G_{ref}}$.
- I_0= diode saturation current (temp dependent).
- R_s, R_{sh}= series and shunt resistances.
- n= diode ideality factor.
- $V_T = \frac{kT}{q}$(thermal voltage).

Power: $P_{pv} = V \cdot I$.
MPPT (e.g., Perturb & Observe or Incremental Conductance) maximizes P_{pv}.

B. Wind turbine (electromechanical model):
Mechanical power captured:

$$P_{wind} = \frac{1}{2}\rho A C_p(\lambda, \beta) V_w^3$$

Where:

- ρ= air density, $A = \pi R^2$, $V_w$wind speed.
- $C_p(\lambda, \beta)$= power coefficient (from turbine curve).
- Tip-speed ratio: $\lambda = \frac{\omega_r R}{V_w}$.

Electrical model: turbine → generator (e.g., PMSG) → AC-DC converter. MPPT: maximize $P_{wind}$by operating generator speed to maintain optimal λ.

C. Fuel cell (simplified electrochemical model):
Polarization curve (simplified):

$$V_{fc} = E_0 - a\ln(I_{fc}) - R_{int}I_{fc}$$

Where:

- E_0= open-circuit voltage (function of temperature).
- a= activation loss coefficient.
- R_{int}= internal resistance.
- I_{fc}= fuel cell current.

Fuel cell power: $P_{fc} = V_{fc} \cdot I_{fc}$. Fuel cell dynamics often slower — model as first-order dynamics:

$$\tau_{fc}\frac{dP_{fc}}{dt} + P_{fc} = P_{ref}$$

to capture ramp-rate limits.

D. Converters & losses
Model DC-DC converters and inverter with efficiency factors or switching model:
$P_{out} = \eta P_{in}$(or model switching averaged equations for control design).

E. DC bus energy balance
At each time step:

$$C_{dc}\frac{dV_{dc}}{dt} = I_{pv} + I_{wind} + I_{fc} + I_{st} - I_{load} - I_{losses}$$

Where $C_{dc}$is DC link capacitance and currents relate to powers via $I = P/V_{dc}$.

2.Simulation setup & parameters

- Time step: 1 ms–10 ms for switching-averaged models; 50 ms–500 ms for quasi steady-state energy management.
- PV array: use number of modules, single-diode parameters (Isc, Voc, Ns).
- Wind turbine: R, Cp curve (from manufacturer), generator inertia J, generator model (PMSG or induction).
- Fuel cell: E_0, R_{int}, ramp-time constant τ_{fc}.

- DC link capacitance C_{dc} chosen to limit voltage droop.

III. POWER MANAGEMENT

The power management strategy of the hybrid PV–Wind–Fuel-Cell system ensures reliable load supply while maximizing renewable energy utilization and maintaining stable DC-bus voltage. The energy management controller continuously monitors the available PV and wind power, load demand, storage state-of-charge, and fuel-cell operating limits to allocate power in the most efficient manner. When renewable generation exceeds the load, excess energy is first used to charge the storage unit and any further surplus is curtailed to prevent overvoltage. During periods of insufficient renewable power, the controller dispatches the fuel cell within its ramp and capacity limits to provide steady support, while the storage unit handles fast transient variations to maintain voltage quality. If both renewable and local sources are inadequate, the system imports power from the grid or, in islanded mode, sheds non-critical loads to ensure supply continuity. This coordinated power management approach balances dynamic resources, enhances system reliability, reduces fuel consumption, and ensures optimal operation under varying environmental and load conditions.

Modes of operation

1. **Grid-connected — economic mode**: allow grid import/export; use grid for peak shaving; minimize fuel cost using price signals.
2. **Islanded — reliability mode**: all local resources must balance load; strict droop & EMS control; curtail non-critical loads when needed.
3. **Black start**: if grid down and fuel cell available, use fuel cell + storage to start inverter in grid-forming mode then reconnect renewables.

State transitions should be event-driven (grid failure detected, SOC threshold met, etc.).

Implementation details & sampling rates

- MPPT: 0.1–1 s (slow).
- DC bus PI & inverter inner loops: 1–10 ms (fast).
- EMS supervisory: 100 ms–1 s for rule-based; 1–5 min horizons for MPC scheduling.
- Ramp filters for fuel cell: time constant τ_fc = 10–60 s (tunable).

Example numerical parameters (starter)

- PV + Wind sampling for EMS: 200 ms.
- DC bus V_ref = 700 V (or 400 V per design).
- P_fc_max = 40 kW, P_st_max_charge/discharge = 20 kW, E_st = 50 kWh.
- Fuel cell ramp limit R_fc = 2 kW/s.
- DC bus PI: Kp = 0.2, Ki = 1.0 (tune in sim).

Fault handling & graceful degradation

- If storage fails: rely more on fuel cell; increase conservative FC reserve.
- If FC fails: increase reliance on storage and curtail non-critical loads.
- If inverter fault: switch to backup inverter or start grid feed (if connected).
- Always log events and provide hysteresis to avoid rapid mode flapping.

IV. Importance Of Advanced Energy Coordination for Hybrid Renewable Systems

Advanced energy coordination plays a vital role in improving the performance, reliability, and sustainability of hybrid renewable energy systems. Since solar, wind, and fuel cell sources exhibit different characteristics and variability patterns, coordinated energy management is essential to balance their contributions and ensure continuous power availability. Effective coordination enhances the overall system efficiency by prioritizing renewable generation, minimizing fuel consumption, and reducing operational costs. It also ensures stable voltage and frequency regulation, which are critical for maintaining power quality in both grid-connected and standalone modes. Furthermore, advanced coordination strategies enable better resource utilization, extend the lifespan of system components, and support real-time adaptation to fluctuating environmental conditions. By integrating intelligent control, optimization algorithms, and smart decision-making, advanced energy coordination contributes

significantly to the development of resilient microgrids, rural electrification solutions, and sustainable energy infrastructures. Ultimately, it supports global goals of clean energy transition and environmental protection by maximizing renewable energy penetration.

V. BENEFITS

Advanced energy coordination in hybrid renewable systems offers numerous technical, economic, and environmental advantages. One of the primary benefits is improved **power reliability**, as coordinated control ensures continuous energy supply even when individual sources such as PV or wind fluctuate. By intelligently managing multiple energy inputs, the system achieves **higher efficiency** and **optimal utilization of renewable resources**, reducing the need for backup generators or excessive fuel consumption. This coordination also leads to **enhanced power quality**, with better voltage regulation, reduced fluctuations, and improved system stability.

Economically, advanced coordination lowers **operational and maintenance costs** by reducing stress on critical components, extending the lifespan of batteries, converters, and fuel cells. The system becomes more flexible and scalable, making it suitable for microgrids, rural electrification, and remote locations. Environmentally, the increased penetration of clean energy sources contributes to **lower greenhouse gas emissions**, reduced dependency on fossil fuels, and overall improvement in sustainability.

In summary, advanced energy coordination enhances system performance, reliability, cost efficiency, and environmental friendliness, making it a key technology for modern renewable energy systems.

VI. SIMULATION RESULTS




Figure.3: Sun light (Irradiance)

Figure.3 illustratesthe solar panel irradiance over time. Initially, the sunlight intensity is high at 1000 W/m². At 0.7 seconds, the irradiance drops to 200 W/m². After some time, around 1.5 seconds, the irradiance returns to the normal condition of 1000 W/m².




Figure.4: Solar System Outputs

Figure 4 shows the solar system's current, voltage, and power output in relation to the solar irradiance. At 0.7 seconds, as the irradiance decreases, the solar system's power output is reduced accordingly, reflecting the change in sunlight intensity.

VII. CONCLUSION

Advanced energy coordination plays a pivotal role in enhancing the performance and reliability of hybrid renewable energy systems integrating PV, wind, and fuel cell technologies. By intelligently managing the variable outputs of solar and wind resources and effectively utilizing the fuel cell as a stable backup source, coordinated energy management ensures continuous power supply under diverse operating conditions. The implementation of optimized control strategies enables stable voltage regulation, efficient power distribution, and reduced dependence on non-renewable energy sources.

REFERENCES

1. S. B. Kjaer, J. K. Pedersen, and F. Blaabjerg, "A review of single-phase grid-connected inverters for photovoltaic modules," *IEEE Trans. Ind. Appl.*, vol. 41, no. 5, pp. 1292–1306, 2005.
2. H. Ibrahim, A. Ilinca, and J. Perron, "Energy storage systems—Characteristics and comparisons," *Renew. Sustain. Energy Rev.*, vol. 12, no. 5, pp. 1221–1250, 2008.
3. M. Kalantar and S. M. Mousavi, "Dynamic behavior of a standalone hybrid power generation system of wind turbine–fuel cell–battery storage," *Appl. Energy*, vol. 87, no. 10, pp. 3051–3064, 2010.
4. N. A. Ahmed, M. Miyatake, and A. K. Al-Othman, "Power fluctuation suppression of standalone hybrid generation system using efficient power management controller," *IEEE Trans. Ind. Electron.*, vol. 55, no. 10, pp. 2227–2235, 2008.
5. R. Karthikeyan and S. Palaniswami, "Fuzzy logic-based energy management system for a PV–Wind–Fuel Cell hybrid system," *Int. J. Electr. Power Energy Syst.*, vol. 64, pp. 1092–1100, 2015.
6. T. T. Lie and K. S. Ge, "Energy management algorithms for hybrid renewable energy systems," *Electr. Power Energy Syst.*, vol. 78, pp. 48–58, 2016.
7. F. Z. Peng, "Z-source inverter," *IEEE Trans. Ind. Appl.*, vol. 39, no. 2, pp. 504–510, 2003.
8. R. Dufo-López and J. L. Bernal-Agustín, "Design and control strategies of PV–Diesel systems

using genetic algorithms," *Sol. Energy*, vol. 79, no. 1, pp. 33–46, 2005.
9. M. E. Glavin and W. G. Hurley, "A hybrid battery–supercapacitor energy storage system for stand-alone PV power applications," *Power Electron. Specialists Conf.*, pp. 1–10, 2008.
10. A. Zahedi, "Maximizing solar PV energy penetration using energy storage technology," *Renew. Sustain. Energy Rev.*, vol. 15, no. 1, pp. 866–870, 2011.
11. S. Rehman, L. M. Al-Hadhrami, and M. M. Alam, "Pumped hydro energy storage system: A technological review," *Renew. Sustain. Energy Rev.*, vol. 44, pp. 586–598, 2015.
12. K. Bhattacharjee, S. Chatterjee, and S. Bandyopadhyay, "Optimal planning of hybrid renewable energy systems using HOMER," *Energy Procedia*, vol. 90, pp. 524–531, 2016.
13. L. Wang and C. Singh, "PSO-based multi-objective optimization of hybrid renewable energy systems," *IEEE Trans. Sustain. Energy*, vol. 2, no. 2, pp. 109–121, 2011.
14. B. Parida, S. Iniyan, and R. Goic, "A review of solar PV-based power generation," *Renew. Sustain. Energy Rev.*, vol. 15, pp. 1625–1636, 2011.
15. N. Jenkins, "Wind energy technology and grid integration," *Proc. IEEE*, vol. 89, no. 12, pp. 1701–1714, 2001.
16. A. Chauhan and R. P. Saini, "Renewable energy-based multigeneration systems: A review," *Renew. Sustain. Energy Rev.*, vol. 76, pp. 129–143, 2017.
17. R. Peña, J. C. Clare, and G. M. Asher, "Doubly fed induction generator using back-to-back PWM converters," *IEE Proc. Electr. Power Appl.*, vol. 143, no. 3, pp. 231–241, 1996.
18. P. Champenois et al., "Modeling and control of hybrid renewable energy systems," *Renew. Energy*, vol. 33, pp. 422–430, 2008.
19. Y. Sawle, S. Gupta, and A. Kumar, "Optimization of hybrid renewable energy system using HOMER," *Renew. Energy Focus*, vol. 22, pp. 52–63, 2017.
20. N. Fathima and K. Palanisamy, "Optimization in microgrids with hybrid renewable energy systems," *Renew. Sustain. Energy Rev.*, vol. 45, pp. 431–446, 2015.
21. S. M. Shaahid and I. El-Amin, "PV–Diesel hybrid energy system for rural electrification," *Energy*, vol. 33, pp. 130–134, 2008.
22. J. T. Bialasiewicz, "Renewable energy systems with photovoltaic power generators," *IEEE Trans. Ind. Electron.*, vol. 55, no. 7, pp. 2752–2758, 2008.
23. R. Lasseter, "Microgrids and distributed generation," *J. Energy Eng.*, vol. 133, no. 3, pp. 144–149, 2007.
24. H. Belmili et al., "PV array modeling based on datasheet values," *Energy Procedia*, vol. 36, pp. 323–332, 2013.